



PLAN VIEW

NOTE:

ANNUAL SURVEY OF A-C POTENTIAL TO BE MADE OF PIPELINE TO INSURE MAXIMUM OF 20 VOLTS INDUCED POTENTIAL NOT PRESENT.



ELEVATION



STANDARD ENCROACHMENT DETAILS
FOR INSTALLATION OF UNDERGROUND POWER LINES AND
FIBER OPTIC LINES PARALLEL TO SSSGP'S PIPELINE

REV.	DATE	BY	DESCRIPTION	APP	SCALE: 1" = 1'-0"
0	05-05-2004	GLS	REVISED PER SSSGP STANDARDS	RDH	P. I. N.
1	11-05-2007	JAK	REPLACED STD. DWG. 005-090-A-0076	RDH	DWG. NO.
					STD-ENC-P-UPL

DRAWN BY: GLS	DATE: 05-04-2004
CHECKED BY:	DATE:
APPROVED BY: RDH	DATE: 05-28-2004